

PROPERTY	UNIT	GUARANTEE	LIMIT	TEST METHOD
Appearance	Homogeneous, visible phase separation, granular or fibrous material should not and must not contain visible impurities observed			Visual
Density at 15°C	kg/m ³	998	Max	TS 1013 EN ISO 3675 or TS EN ISO 12185
Flash Point	°C	60	Min	TS EN ISO 2719
Kinematic Viscosity at 100°C	mm ² /s	50	Max	TS 1451 EN ISO 3104
Sulfur	%(m/m)	0,1-1,0		TS EN ISO 8754
Ash	%(m/m)	0,20	Max	TS EN ISO 6245
Water	%(v/v)	1,0	max	TS 124 EN 1428
Total Sediment aged	%(m/m)	0,15	Max	TS ISO 10307-2

This product is produced in İzmir and İzmit Refinery.